


## Certificate of Product Approval

Certificate Number: 1283a

Issue: 08

### POLON-ALFA S.A.

ul. Glinki 155  
85-861 Bydgoszcz  
Poland



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**Beam Detector**  
DOP-6001R  
(refer to Appendix for details)

#### Standards

**EN 54-12:2002**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan  
Verifier

27 July 2018  
Date of Issue

12 June 2015  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1283a

Issue: 08

### POLON-ALFA S.A.

| Certified Product | Description   | LPCB Ref.No. |
|-------------------|---|--------------|
| DOP-6001R         | <p>Conventional Optical Beam Smoke Detector (Double Pass)</p> <p>Notes:</p> <ol style="list-style-type: none"> <li>1. Meets the requirements of EN 54-12 at the following sensitivity settings only:                             <ul style="list-style-type: none"> <li>- 18% obscuration high sensitivity at between 5-20m</li> <li>- 30% obscuration medium sensitivity at between 20-100m</li> </ul> </li> <li>2. Suitable for use with E39-R8 prismatic reflector over distances from 5 to 50m</li> <li>3. Suitable for use with 4 x E39-R8 set of reflectors over distances from 50 to 100m</li> </ol> | 1283a/01     |

#### Ancillaries

E39-R8                      Single prism reflector  
 4 x E39-R8                Set of 4 x prism reflectors

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan  
 Verifier

27 July 2018  
 Date of Issue

12 June 2015  
 Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
 T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.